



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

September 30, 2011

POLYLOK, INC.  
**PETER GAVIN**  
60 CAPITOL DR  
WALLINGFORD CT 06492

Re: Description: SEWAGE TANK COVERS, LIDS, RISERS  
Manufacturer: POLYLOK, INC.  
Product Name: SEPTIC TANK RISER  
Model Number(s): 20 IN. DIA. RISER AND COVER (3009 AND 3009-RC)  
24 IN. DIA. RISER AND COVER (3008 AND 3008-RC)

**[6 IN. HIGH RISERS FOR CASTING TO CONCRETE STATE-APPROVED TANKS OR  
INSTALLED AS RETROFIT, SINGLY OR STACKED]**

Product File No: 20110299

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of JANUARY 2017.**

This approval is contingent upon compliance with the following stipulation(s):

- Before this product is installed a warning label meeting the requirement of Comm s. 84.25(8)(b), Wis. Admin. Code must be securely attached to the manhole cover.
- Joints between riser sections shall be sealed with neoprene gasket supplied by the manufacturer and the riser must be installed on state-approved tanks in accordance with the riser manufacturer's installation instructions.
- Riser covers must only have tamper proof screws installed.
- For high groundwater installations, refer to manufacturer's installation recommendations.
- **Additional information is included as attachment(s) to this letter; see attachment A.**

This approval supersedes the approval issued on 7/25/2008 under product file number 20070001.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070001.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Products Review  
DPS WEST, Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@WI.GOV